

ADDENDUM No. 6

TO: ALL BIDDERS

FROM: CITY OF HIALEAH

ITB #: 2018-19-3210-00-009

**RE: ITB – NW 97TH AVE FROM NW 154TH ST TO NW 162ND ST – PHASE 1 –
ROADWAY AND DRAINAGE IMPROVEMENTS**

DATE: March 28, 2019

The original contract documents for the entitled: **ITB – NW 97TH AVE FROM NW 154TH ST TO NW 162ND ST – PHASE 1 – ROADWAY AND DRAINAGE IMPROVEMENTS** needs to be amended as noted in this Addendum No. 6.

This Addendum No. 6 consists of 3 typed pages, 0 attachments and 1 addendum receipt form (ARF). All other items and conditions of the original contract documents shall remain unchanged. This Addendum No. 6 shall become a part of the contract documents.

Approved for the issue: *LUIS SUAREZ* Date: March 28, 2019
Luis A. Suarez – Acting Purchasing Manager

ACKNOWLEDGMENT

Receipt of this Addendum No. 6 shall be acknowledged in the space provided on the ADDENDUM RECEIPT form – ARF (Copy attached) now a part of the Contract Documents to be faxed immediately to the City of Hialeah Purchasing Division (305) 883-5871 and submitted with sealed bids.

QUESTIONS AND ANSWERS:

The City received the following question(s), clarification(s) or suggestion(s) by email from Roadway Construction LLC., (“RC”) on March 20, 2019:

RC Question No. 1: After review of the City’s response to ATI Question No. 4 “Signalization at NW 158th St” (1 EA). There is no plan for such intersection signalization. How are we supposed to provide a lumpsum price without any scope of work, actual lengths for mast arms, pedestrian signals, loops, conduits, video detections, etc.? Either a plan needs to be submitted to all bidders so there is a basis to go off of or the item should be removed from the bid item list. Please advise.

City’s response: Response to ATI Question No. 4 is hereby being withdrawn and replaced with the following: All bidders are to provide an estimated bid of \$275,000.00 for the signalization pay item. Final cost will be negotiated with the winning bidder, via change order, upon completion and approval of signalization plans.

RC Question No. 2: After review of the City's response to ATI Questions No. 2 "FPL Pole Relocation" (6 EA). Please remove this item from the bid item list and resend out for all bidders.

City's response: Item will not be removed from the bid item list. All bidders are to bid \$0.00 for this item.

The City received the following question(s), clarification(s) or suggestion(s) by email from CONTECH Engineered Solutions, ("CES") on March 19, 2019:

HRP Question No. 1: Page 3 of addendum #4 states... "96" culvert pipe needs to be CMP corrugated steel pipe (3"x1") 8ga as it was approved on NW 142nd St. and NW 97th ave."

All of the culverts installed on 97th Ave to date have been 96" Alt2 steel (3"x1"-12ga) since 96" (3"x1"-8ga) Alt2 steel is not available. Attached are copies of the approved shop drawing for NW 142nd St. and NW 97th Ave. (Aquabella North) approving the use of 96" (3"x1"-12ga).

City's response: Referenced pipes are to be changed from 96" Alt2 Steel (3"x1"-8ga) to 96" Alt2 steel (3"x1"-12ga).

CITY OF HIALEAH

**ITB – NW 97TH AVE FROM NW 154TH ST TO NW 162ND ST – PHASE 1 –
ROADWAY AND DRAINAGE IMPROVEMENTS**

ADDENDUM No. 6

ADDENDUM RECEIPT FORM

CONTRACTOR'S NAME _____

ADDRESS _____

PHONE NO. _____

CONTACT NAME _____ SIGNATURE _____

THE BIDDER ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUM BY SIGNING AND DATING
BELOW: (Copy of this form must be faxed immediately to the City of Hialeah at (305) 883-5871).

<u>ADDENDUM</u>	<u>SIGNATURE</u>	<u>DATE</u>
6	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____